

**ADDENDUM NO.3
TO THE BIDDING/CONTRACT DOCUMENTS AND SPECIFICATIONS
CITY OF HOLLY HILL
FY 2010-2011 SANITARY SEWER REHABILITATION PROGRAM**

July 14, 2011

To All Plan Holders:

The following changes, clarifications, and additions are hereby made part of the bidding and project plans and/or specifications for the above referenced project dated June 2011 and prepared by Quentin L. Hampton Associates, Inc. as fully and completely as if the same were fully set forth therein.

1. **Specification Section 02730** – The City will provide water for cleaning and testing at no charge. The Contractor shall obtain a hydrant meter and leave the required deposit. All usage shall be measured and reported weekly.
2. **Specification Section 02746, paragraph 3.04 F. (B.)** – Leakage testing can be performed prior to cutting ends of CIPP.
3. **Specification Section 01580, paragraph 2.01 D.** – A project sign is not required.
4. The bid date and time remains unchanged.

Disclaimer: This addendum was sent via e-mail. The delivery confirmation is acknowledgement that the addendum has been received. It is the sole responsibility of the bidder to confirm that all addenda have been received prior to submitting bid and acknowledge such in the bid documents.