

**ADDENDUM NO.4  
TO THE BIDDING/CONTRACT DOCUMENTS AND SPECIFICATIONS  
CITY OF HOLLY HILL  
FY 2010-2011 SANITARY SEWER REHABILITATION PROGRAM**

**July 15, 2011**

To All Plan Holders:

The following changes, clarifications, and additions are hereby made part of the bidding and project plans and/or specifications for the above referenced project dated June 2011 and prepared by Quentin L. Hampton Associates, Inc. as fully and completely as if the same were fully set forth therein.

1. **Specification Section 02730, 2746A and 2748A** - The schedule of values has no bid item for 'Lateral Lining'. Section 2746A is for reference purposes only and will only be used if the City decides to add this work at a later date. Specification Section 02748A refers to bid item 8(b) 'Top Hat' Service Lateral Connections (SLC) for bidding purposes. The minimum SLC length shall be 12". The maximum length is 18". SLC Sealing beyond 18" shall be negotiated as a change order on a case by case basis, if required.

The SLC product used shall be compatible with the lining system used in the main line. Technical requirements detailed in ASTM F2561-06 shall apply for work performed under bid item 8(b) and any full length laterals which may be identified in the field.

2. The bid date and time remains unchanged.

**Disclaimer: This addendum was sent via e-mail. The delivery confirmation is acknowledgement that the addendum has been received. It is the sole responsibility of the bidder to confirm that all addenda have been received prior to submitting bid and acknowledge such in the bid documents.**