



NOTE:

1. BOLT VALVES TO TEE OR CROSS WHEREVER AND WHENEVER APPLICABLE.
2. A CONTINUOUS TRACER WIRE TO BE COLOR CODED "PURPLE" FOR RECLAIMED WATER, LAYED ON TOP IN TRENCH
3. GATE VALVE WEDGE SHALL BE COMPLETELY ENCAPSULATED WITH EPDM RUBBER.
4. ALL EXTERIOR BOLTS, NUTS, WASHERS AND HARDWARE SHALL BE MINIMUM OF 316 STAINLESS STEEL GRADE.



STANDARD CONSTRUCTION DETAIL
 RECLAIMED WATER
 VALVE AND VALVE BOX
 (4" – 16" VALVE SIZES)

FILE NAME:

RW11.DWG

DETAIL REF:

RW-11